

## Transformer Evaluation

### Three (3) 2500 Kva Pad Mount Transformer, 7200 Volt, 277/480 Three Phase

BIDDER	QUANTITY	PRICE	A	B	NO LOAD LOSS	LOAD LOSS	TOTAL	EXTENDED TOTAL	TOTAL COST
HD Supply (GE)	3	\$ 29,565.00	5.794	1.067	2,008	17,928	\$ 60,328.53	\$ 180,985.58	\$ 269,680.58
KBS (Ermco)	3	\$ 30,395.00	5.794	1.067	2,440	13,232	\$ 58,650.90	\$ 175,952.71	\$ 267,137.71
Stuart Irby (Cooper)	3	\$ 30,025.15	5.794	1.067	2,196	17,409	\$ 61,324.18	\$ 183,972.53	\$ 274,047.98
Stuart Irby (Ermco)	3	\$ 29,601.05	5.794	1.067	2,440	13,232	\$ 57,856.95	\$ 173,570.86	\$ 262,374.01
Techline (Howard)	3	\$ 31,202.00	5.794	1.067			\$ 31,202.00	\$ 93,606.00	\$ 187,212.00
Wesco (ABB)	3	\$ 27,616.58	5.794	1.067	2,695	14,923	\$ 59,154.25	\$ 177,462.75	\$ 260,312.49
			5.794	1.067			\$ -	\$ -	\$ -

Formula: Price + (AxNNL) + (BxLL)=Total x Quantity = Extended Total + Price x Quantity = Total Cost

### 0 (0) Kva Pad Mount Transformer, 7200 Volt, 12/208 Three Phase

BIDDER	QUANTITY	PRICE	A	B	NO LOAD LOSS	LOAD LOSS	TOTAL	EXTENDED TOTAL	TOTAL COST
			5.794	1.067			\$ -	\$ -	\$ -
			5.794	1.067			\$ -	\$ -	\$ -
			5.794	1.067			\$ -	\$ -	\$ -
			5.794	1.067			\$ -	\$ -	\$ -
			5.794	1.067			\$ -	\$ -	\$ -
			5.794	1.067			\$ -	\$ -	\$ -
			5.794	1.067			\$ -	\$ -	\$ -

Formula: Price + (AxNNL) + (BxLL)=Total x Quantity = Extended Total + Price x Quantity = Total Cost

