

CITY OF SEGUIN

To: City Council
From: Adam Rossing, Director of Public Works
Date: June 16, 2026
Subject: Requesting approval of the city council to authorize the City Manager to execute an agreement with Lewis Concrete Restoration through the HGACBuy Cooperative Purchasing Program Contract TP07-25 for the trenchless rehabilitation and repair of an existing 84-inch storm sewer pipe in the amount of \$527,000.



It's real.

Historical Background

The City has identified significant deterioration within an existing 84-inch reinforced concrete and corrugated metal storm sewer pipe located within the Hospital drainage corridor. The condition of the pipe presents concerns related to structural integrity, continued erosion, and potential failure of the stormwater system. Due to the size and depth of the infrastructure, trenchless rehabilitation is the most effective and least disruptive method for completing the repairs while maintaining system operation and minimizing impacts to adjacent properties and infrastructure.

The proposed work includes pipe joint and connection repairs, invert rehabilitation, and void repairs utilizing specialized trenchless restoration methods. The repairs are imperative to protect public safety, maintain critical stormwater conveyance capacity, and prevent further deterioration that could result in roadway, drainage, or adjacent property damage.

Staff recommends utilizing the HGACBuy cooperative purchasing contract TP07-25, which satisfies state procurement requirements and allows the City to expedite the necessary repairs in a timely and cost-effective manner.

Action Requested

Requesting approval execute an agreement with Lewis Concrete Restoration through the HGACBuy Cooperative Purchasing Program Contract TP07-25 for the trenchless rehabilitation and repair of an existing 84-inch storm sewer pipe in the amount of \$527,000.

Procurement Methodology & Funding Source

Funding for the project will be provided through the GLO Supplemental Fund designated for drainage improvement projects. Procurement of the services will be conducted through the HGACBuy Cooperative Purchasing Program utilizing Contract TP07-25.

Recommendation

Staff recommends approval of the agreement with Lewis Concrete Restoration through HGACBuy Contract TP07-25 for the trenchless repair and rehabilitation of the 84-inch storm sewer pipe.

ATTACHMENTS

1. Memo to Council
2. Quote